



ADDENDUM NO. 3

Project Name: City of South Miami MURRAY PARK COMMUNITY POOL RFP-NO.
SM –PW2010-10

Date: September 8, 2010

Sent: E-mail/webpage

This addendum submission is issued to clarify, supplement and/or modify the previously issued BID Documents, and is hereby made part of the BID Documents. All requirements of the BID Documents not modified herein shall remain in full force and effects as originally set forth. Receipt of this Addendum shall be acknowledged on the Bid Form.

Murray Park Pool Pre Bid Meeting
Questions & Answers
Addendum # 3

1. Is 100% of the heating for the pool to be provided with solar collectors? Yes
2. To what temperature does the water need to be heated? 80° Fahrenheit, from May to October
3. Is a code minimum toilet room count acceptable for the pool toilet facility? Yes
4. Does the toilet facility require air conditioning? No, may implement louvers and fans
5. Does anything else require air conditioning? No

General Comments

1. Use passive cooling for bathroom with louvers and fans
2. integrate a pavilion, include fans
3. There needs to be a controlled entrance
4. Include a splash area for small children
5. Consider a lightning fence for the pool
6. Security system to indicate unauthorized use at night
7. Please provide a proposed schedule allowing for community input in design
8. Apply shade over the Children's area
9. Incorporate many colors.
10. City of South Miami will no longer be accepting any more questions in reference to this RFP effective 09/08/10 5:00 PM

Additional Information posted on line

Survey
Geotechnical Report
Project area for Murray Pool